



ST. JOHNS COUNTY, FLORIDA

OPTIONAL STANDBY SYSTEMS NEC Article 220, 445, 702, FIXED GENERATOR SYSTEMS

Generator Size (WATTS) - _____

Transfer Switch: Automatic _____ Manual _____

Automatic transfer switch: Provide calculated load to be utilized. _____ Amps. When connected to a transfer panel the automatic transfer switch shall be rated equal to the transfer panel.

Manual Transfer Switches: selected loads may be chosen and identified for use when the generator is in operation, without the use of a transfer panel.

Manual Transfer Switch ONLY: (Provide manufacturer specifications) _____

Transfer switches and proper receptacles will be permitted and inspected for portable generator with a listed cord set.

Fuel Source: **Existing** _____ **New** _____ (separate gas/piping permit required)

Fuel Source Type: **Gasoline** _____ **Propane** _____ **Diesel** _____ **Natural Gas** _____

Note:

Optional Fixed Generator Systems and Fuel Storage Tanks must meet all applicable local, state, and federal code related requirements.

Machinery and Equipment servicing the building must meet the minimum elevation requirement and zoning set-back requirements.

All Commercial Fuel Storage Tanks require approval through SJC Fire Service Department and Development Services Department.