

## ADA Transition Plan

Under Title II of the Americans with Disabilities Act (ADA), public entities are required to perform self-evaluations of their current facilities and infrastructure to determine compliance with ADA standards. As a result of these evaluations, a Transition Plan must be developed to address identified deficiencies. The St. Johns County Transition Plan is required to be updated periodically and includes the following information:

- Facility or element that contains an obstacle to ADA compliance
- Necessary modifications needed in order to achieve compliance
- Estimated timeline for modifications, from securing funding to project completion
- Identifying the department responsible for the facility or element
- Date at which compliance is achieved

Facility/Feature	Location Address	Obstacle	Accessibility Method	Oversight	Anticipated Schedule	Completed Date
Fire Station 10	155 Library Dr.	Restroom Signage	Add accessible signage	FM/Cyndi Krause	FY 2019	
Davis Park	210 Davis Park Rd.	baseball fields inaccessible	Add accessible route connecting baseball fields to parking and existing accessible features	Construction Svc/Bill Freeman	Capital Improvement Cycle FY 2020-FY 2025	
Sidewalks	W. King St/Holmes Blvd	No accessible sidewalks	Add accessible sidewalks w/ADA ramps	Public Works/Nick Perpich	FY 2017	Summer 2017
Sidewalks	Woodlawn Rd	No accessible sidewalks	Add accessible sidewalks	Public Works/Donnie Tackett	FY 2018	April 2018
Sidewalks	SR 16/Inman Rd	No accessible sidewalks	Add accessible sidewalks	Public Works/Doug Tarbox	FY 2017	2017
Sidewalks	Wildwood Dr/US 1	Inaccessible sidewalks/intersection lighting	Add ADA ramps and intersection lighting	Public Works/Nick Perpich	FY 2020	
Sidewalks	Lewis Point Rd/US 1	Inaccessible sidewalks/intersection lighting	Add ADA ramps and intersection lighting	Public Works/Nick Perpich	FY 2020	
Sidewalks	Shore Dr/US 1	Inaccessible sidewalks/intersection lighting	Add ADA ramps and intersection lighting	Public Works/Nick Perpich	FY 2020	
Sidewalks	Old Moultrie Rd	No accessible sidewalks	Add accessible sidewalks on both sides of roadway	Public Works/Nick Perpich	FY 2021	
Amphitheatre	1340 A1A South	no ADA ramps or accessible seating for mid level	add ramps to each side and seating	Construction Svc/Bill Freeman	FY 2020	

Sidewalks	Eagle Creek- Island Landing Dr	sidewalk/ramps	upgraded to accessible sidewalks/ramps	Public Works/ Tommy Mashburn		FY 2016
Sidewalks	Shores Blvd/Christina Dr to US1	sidewalk/ramps	upgraded to accessible sidewalks/ramps	Public Works/ Tommy Mashburn/N. Perpich		FY 2016/FY 2017
Sidewalks	Greenbriar Rd/between SR13 to Branbly Vine Dr	sidewalk/ramps	upgraded to accessible sidewalks/ramps	Public Works/ Tommy Mashburn		FY 2018
Sidewalks	Shores Blvd/209 Shores Blvd to 477 Shores Blvd	mid-block crossings	upgraded 2 crossings and added ADA mats	Public Works/ Tommy Mashburn		FY 2018
Sidewalks	San Rosa Subdivision	sidewalk/ramps	upgrade to accessible sidewalks/ramps	Public Works/ Tommy Mashburn	FY 2019	
Sidewalks	IGP/between SR 16 and WGV Blvd	ramps	upgrade ramps where needed	Public Works/ Tommy Mashburn	FY 2019	
Agriculture Center		restroom , water fountain accessibility	add accessible signage, replace ball knobs w/levers, water fountain height	FM/Justin Howell	FY 2019-2020	
Pet Center		Parking, restrooms	Add ADA parking, add accessibility to restrooms	Animal Control/ Paul Studivant		Complete
Walter E. Harris	400 E. Harris St	accessible restrooms needed	add correct number of accessible restrooms	FM/ Justin Howell	Capital Improvement cycle FY 2020-FY 2025	
Stratton Road Transfer Station		accessible restroom signs needed	add accessible signage	FM/Justin Howell	FY 2019	